

NOTES:

1. CUSTOMER IS RESPONSIBLE TO PROVIDE ALL LABOR, EQUIPMENT, AND MATERIALS (INCLUDING ALL METERS).
2. PROVIDE ZOLLER MODEL M53 SUMP PUMP WITH FLOAT SWITCH LEVEL CONTROL. POWER TO BE PROVIDED BY PROPERTY OWNER. ALTERNATIVELY, IF GRADING PERMITS, A GRAVITY DRAIN WITH SANITARY CHECK VALVE MAY BE PROVIDED.
3. HATCH SHALL BE BILCO TYPE 'J' WITH LOCKABLE HASP AND STAINLESS STEEL HARDWARE.
4. VAULT SHALL BE WATERTIGHT PRE-CAST OR CAST-IN-PLACE CONCRETE DESIGNED TO SUPPORT AN AASHTO H20 LIVE LOAD.
5. VALVE VAULT, PIPING AND ALL EQUIPMENT SHALL BECOME THE OWNERSHIP OF WESTERN WATER UPON ACCEPTANCE.
6. SUBMIT SHOP DRAWINGS TO WESTERN WATER FOR APPROVAL. INCLUDE ALL MATERIALS OF CONSTRUCTION AND PROVIDE STRUCTURAL DESIGN CERTIFICATION BY AN OHIO REGISTERED PROFESSIONAL ENGINEER.
7. ALL PIPE SHALL BE DUCTILE IRON, PRESSURE CLASS 250.